

CORRES CONTROL
OUTGOING LTR #

DOE ORDER #

05-RF-00510

DIST	LTR	ENC
DIETER, T. J.		
DEL VECCHIO, D. C.		
FERRERA, D.W.	X	
GILPIN, H.E.	X	
LONG, J.W.	X	
LINDSAY, D. C.		
MARTINEZ, L.A.		
SHELTON, D.C.		
SPEARS, M.S.		
TUOR, N.R.	X	
GEIS, J.A.		
FREIBOTH, C.		
CARMAN, M.A.		
PLAPPERT, R.D.		
SNYDER, D.P.	X	
BERARDINI, J.	X	
CONYERS, J.	X	
DEGENHART, K.	X	
GIACONINI, J.	X	
POLING, J.	X	
SWARTS, M.	X	
WELK, D.	X	
CLARK, D.W.	X	
HUMISTON, T.	X	



May 24, 2005

05-RF-00510

Ronald G. Bostic, Director
Nuclear Regulatory Division
DOE, RFPO

NOTIFICATION OF FINAL DOWNGRADE OF HAZARD CATEGORIZATION FOR BUILDING 440 REPACKAGING AREA - JAG-016-05

Ref: DOE Memorandum, RFPM:RGB:05-00282, Downgrade of Hazard Categorization for Building 440, dated April 29, 2005

The purpose of this letter is to notify the Rocky Flats Project Office of the final downgrade of the hazard categorization of the repackaging area of Building 440, to non-nuclear, industrial category. The referenced memorandum directed such notification following completion of equipment removal from the repackaging area.

The final holdup measurement scans of this area are attached, which document the technical basis for the final downgrade. Measured values are no different than background, demonstrating that all holdup was removed with the repackaging equipment.

If there are any questions concerning this transmittal, please contact me at extension 7088.

CORRES CONTROL	X	X
PATS		
ADMN. RECORD		
WASTE REC CTR		
TRAFFIC		

CLASSIFICATION:

UCNI	
UNCLASSIFIED	X
CONFIDENTIAL	
SECRET	

AUTHORIZED CLASSIFIER
SIGNATURE *(Signature)*

Dan Mayfield
Date: 24/May 2005

IN REPLY TO RFP CC #:

(Signature)

J. A. Geis
Program Manager
Nuclear Safety & Licensing

JAG:rlm

Attachment:

As Stated

ACTION ITEM STATUS:

☐ PARTIAL/OPEN
☐ CLOSED

Original and 1 cc - Ronald G. Bostic

LTR APPROVALS:

(Last Name)

(Last Name)


ORIG. & TYPIST INITIALS:

JAG:rlm

Letter # JAG-016-05

Kaiser-Hill Company, L L C


Rocky Flats Environmental Technology Site, 10808 Hwy. 93 Unit B, Golden, CO 80403-8200 • 303-966-7000



ADMIN RECORD



KAISER-HILL
COMPANY, L.L.C.
INTEROFFICE MEMORANDUM

DATE: May 18, 2005
TO: Mike Swartz, Building T690 P, 303-435-6089
FROM: Frank Lamb, Holdup Measurement Team, Building T130 D, X6293 
SUBJECT: WALL-TO-WALL SCANS OF BUILDING 440 GLOVEBOX AND C-CELL AREA

HMT-05.034

The purpose of this correspondence is to report the results of wall-to-wall scans of the Building 440 repack area following removal of the glovebox and C-Cell. The last sections of the C-Cell were removed while we scanned the area. Long count-time measurements were performed throughout the area where previous grams were reported. These measurements included all floor, walls, and ceiling areas in the detector field-of-view.

The results from the wall-to-wall measurements are plotted on the attached chart. The results have been analyzed and there is no indication of SNM above background levels in the repack area of Building 440. Detailed results were previously reported in HMT-05.022. If you have any questions, please contact Frank Lamb at X6293.

cc:

→ Jeff Conyers
Frank Gibbs
Jeff Barroso
Art Geis

Jeanne Poling
Brenda Douglass
Don Clark
SM FILE 6.3

B440 Room 123A Wall-to-Wall

